



# Department of Commerce

Division of State Fire Marshal  
John R. Kasich, Governor  
Jacqueline T. Williams, Director

## Inspection

Inspection		Owner/Occupant	
<b>Inspection #</b>	INS-2015-884399	PRETERM OF CLEVELAND	
<b>Type</b>	30-Freestanding Healthcare Facility	30-18-0288	
<b>Reason</b>	Complaint	12000 Shaker	
<b>Scheduled</b>	04/21/2015 09:00	Cleveland, OH 44120-1922	
<b>Status</b>	Inspection Completed		
Completion of Work		<b>Contacts</b>	<b>Phone</b>
<b>Inspector</b>	David Lawrence	Dawn Lynne Dengler	2169914577
<b>Started On</b>	04/23/2015 10:00	Violation Summary	
<b>Completed</b>	04/23/2015 11:30	<b>Total Violations</b>	0
<b>Assisting Inspectors</b>		<b>Corrected</b>	0
KEITH CARROCCI #0035078		<b>Uncorrected</b>	0

## Summary

On scene here this morning to investigate on Complaint #2015-262. The Complainant alleges a hazard exists, due to a malfunctioning elevator and the absence of having means to evacuate patients from the 3rd floor surgical area. Myself and Chief Carrocci met with Dawn Lynne Dengler the Facility Coordinator for the building. Dawn gave me full access to the entire building and gave me a tour of the facility including the basement, 1st, 2nd 3rd, and 4th floors. Preterm is currently in the process of obtaining permits through the City of Cleveland to begin extensive repairs to its elevator. 2 stairwells are located within this approx 14,000 sq ft building. The front stairwell is considerably wider than the rear and both are in good condition and accessible. No serious life safety violations were found.



## Department of Commerce

Division of State Fire Marshal

John R. Kasich, Governor

Jacqueline T. Williams, Director

### Inspection

### Signatures

A handwritten signature in black ink, appearing to read "Dawn Lynne Dengler", written over a horizontal line.

Dawn Lynne Dengler

04/23/2015

04/23/2015

Date

Date